

TYP 24"x24" LAY-IN PLASTIC DOOR FRAME TYPE CEILING RETURN AIR GRATE 1/2" x 1/2" SQ. OPENING.

24"x6" R.A. OPENING IN WALL ABOVE CLG. TYPICAL OF ALL OPENINGS UNLESS NOTED OTHERWISE.

NOTE: KITCHEN HOOD EXHAUST DUCT TO BE 16 GA.


SEE FIRST FLOOR PLAN - WEST FOR CONTINUATION.

FOR CONT. OF PIPING SEE 1ST FLOOR PLAN - EAST - MECH. SH. T.

FOR CONT. OF DUCT PLAN - EAST - MECH. SH. T.

FOR CONT. OF 1/2" DIA. PIPING SEE 1ST FLOOR PLAN - EAST - MECH. SH. T.

FIRST FLOOR PLAN - EAST - MECHANICAL
1/8" = 1'-0"



		DENEAU, KLESKI & ASSOCIATES ARCHITECTS 40 W. FOURTH ST. - SUITE 2100 - DAYTON, OHIO		DAYTON EXHIBITION CENTER FIFTH AND MAIN STREETS DAYTON OHIO	
		REVISIONS NO. DATE BY DESCRIPTION		DRAWN BY DATE COMM. NO. SHEET NO. CE and PS 11-12-70 68001	
CHECKED BY DATE PRINT DATE TJF 11-13-70 Dec. 3, 1970		M-			