

TYP 24" x 24" LAY IN PLASTIC  
 5/8" GATE TYPE CEILING  
 RETURN AIR GRILLE 1/2" x 1/2"  
 SQ. OPN'G.


FOR CONT. SEE  
 SECOND FL PLAN -  
 WEST - MECHANICAL

NO. 18 GRILLE MOUNTED  
 IN WALL OF MECH. ROOM  
 MANU. DAMPER AS SHOWN BY DASHED LINE  
 24" x 12" RA GRILLE  
 IN MECH. ROOM WALL  
 MOUNTED BELOW 18"  
 BEAM (TYP. OF 2 THIS  
 WALL)  
 24" x 12" DN. TO SUPPLY  
 ELEVATOR W/ MANUAL  
 DAMPER (TYP. OF 5)

12" x 12" EXH. DUCT  
 UP FROM FIRST FL  
 W/ FIRE DAMPER  
 AT CEILING

UPPER PART OF  
 FIRST FLOOR

**SECOND FLOOR PLAN - EAST - MECHANICAL**  
 1/8" = 1' - 0"



**DENEAU, KLESKI & ASSOCIATES**  
 ARCHITECTS  
 40 W. FOURTH ST. - SUITE 2100 - DAYTON, OHIO

**DAYTON EXHIBITION CENTER**  
 FIFTH AND MAIN STREETS  
 DAYTON OHIO

REVISIONS	
NO.	DATE BY DESCRIPTION

DRAWN BY	DATE	COMM. NO.	SHEET NO.
FWK/and	11-12-70	48007	<b>M-4</b>
CHECKED BY	DATE	PRINT DATE	
TJF	11-13-70	Dec. 3, 1970	